Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

M. No. 1853 /EE/PHE/Dn Mungeli Dated: 26/05/2026

It is certified that an inspection team headed by Executive Engineer, Public health Engineering Division Mungeli

inspected the Brilliant Public School, Dharampura on 25-05-2026 and on the basis of Water Test Report (Attached) bearing no. 211 dated 25-05-2026 of District Lab Mungeli certified that the Brilliant Public School, Dharampura has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 25-05-2027

Executive Engineer
P.H.E. Dn. Mungeli
District Mungeli(C.G.)

Signature with Seal: .....
Name : Prasad Kanwar
Designation : Executive Engineer
Name Address of the Office/ Department : PHE Division Mungeli

To
.....
.....
(Name & Address of the Institution)

Brilliant Public School, Mungeli
Manager

Brilliant Public School, Mungeli
Principal

District Water Testing Laboratory
Public Health Engineering Division, Mungeli, Chhattisgarh
Pendarakapa Mungeli, 495334

Email- eemun-phe-cg@nic.in. Telephone: 07755-264172

Test Report

SENDER NAME & ADDRESS:			
BRILLIANT PUBLIC SCHOOL DHARAMPURA-MUNGELI(C.G.)495334	Report No.	:	211
	ULR No.	:	-
	Report Issued Date	:	25.05.2026

SAMPLE PARTICULARS:

Sample Type	Drinking Water (Bore well Sample)	Sender latter No. & Date	
Sampling Location	Not Applicable	Date of Start of Analysis	25.05.2026
Date of Sampling	25.05.2026	Date of Competition of Analysis	25.05.2026
Sample Collected by	CUSTOMER	Environmental Condition	23°C± 5°C
Sample Receipt & date	25.05.2026	Discipline	Chemical
Sample Quantity	1 litter	Group	Water

Sample Details-

No.	Block & District	Village & Panchayat	Sample ID	Location/Source No.
1	MUNGELI	DHARAMPURA	41/115/05/2026	SCHOOL PARISAR
2				
3				

No.	Characteristics	Test method IS:3025		Unit of measurement	As Per BIS-10500:2021 For Drinking Water		Results		
		Method	Part no.		Acceptable Limit	Permissible Limit			
1	2	3	4	5	6	7	115		
1	pH	IS:3025	Part-11	pH scale	6.5 - 8.5	6.5 - 8.5	7.51		
2	Turbidity	IS:3025	Part-10	NTU	1.0	5.0	0.29		
3	Chloride as Cl-	IS:3025	Part-32	mg/L	250	1000	28.98		
4	Total Hardness as CaCO3	IS:3025	Part-21	mg/L	200	600	410.46		
5	Calcium as Ca++	IS:3025	Part-40	mg/L	75	200	98.54		
6	Magnesium as Mg++	IS:3025	Part-46	mg/L	30	100	39.99		
7	Total Alkalinity as CaCO3	IS:3025	Part-23	mg/L	200	600	324.06		
8	Total dissolved solid	IS:3025	Part-16	mg/L	500	2000	610		
9	Color	IS:3025	Part-4	Hazen	5	15	4Hazen		
10	Taste	IS:3025	Part-8	--	Unobjectionable	Unobjectionable	Agreeable		
11	Odour	IS:3025	Part-5	--	Agreeable	Agreeable	Agreeable		

1. *This report should not be produced partly or full without approval of signatory authority of legal purposes*
2. The results refer only to tested samples and parameters tested.
3. Sample will be stored for a period of 10 days from the date of issue of report.
4. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
5. The Laboratory does not give interpretation on Test result PASSED/FAILED.
6. Remarks :- 1. Results apply to the sample as received from customer.
   2. Sampling not done by the Laboratory.

Chemist
(Thajunnia Taap Tande)
Review & Authorized Signatory

Issue No 211/Lab/ Date: 25.05.2026 **End of Report**

Brilliant Public School, Mungeli

Manager

Brilliant Public School, Mungeli

Principal